



**APLUS TRADERS PTY LTD.**

The following sample(s) was/were submitted and identified by the client as:

Sample Description : SPC FLOORING  
Sample Receiving Date : Mar. 29, 2025  
Testing Period : Mar. 29, 2025 TO Apr. 12, 2025  
Testing Location : 3RD BUILDING, LANE 3999, XIUPU ROAD, PUDONG  
NEW AREA, SHANGHAI  
Test Performed : SELECTED TEST(S) AS REQUESTED BY APPLICANT  
Test Requested : RESILIENT AND LAMINATE FLOORING COVERINGS  
CASTOR CHAIR TEST (EN 425:2002)  
Test Result(s) : FOR FURTHER DETAILS, PLEASE REFER TO THE  
FOLLOWING PAGE(S)  
Conclusion : THE SUBMITTED SAMPLE MET THE  
TEST REQUIREMENT.

\*\*\*\*\*

Signed for and on behalf of



SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd.

Yomoro Gu  
Authorized Signatory



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: [CN.Doccheck@sgs.com](mailto:CN.Doccheck@sgs.com)

SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd.  
Testing Center Harbin

4<sup>th</sup> Building, No.888, Yishan Road, Xuhui District Shanghai, China 200233  
中国·上海·徐汇区宜山路888号4号楼 邮编: 200233

t (86) 400 960 9661  
t (86) 400 960 9661

f (86-21) 6115 6899  
f (86-21) 6115 6899

[www.sgs.com.cn](http://www.sgs.com.cn)  
e [sgs.china@sgs.com](mailto:sgs.china@sgs.com)

**Test Conducted:**

**Resilient and laminate floor coverings — Castor chair test (EN 425:2002)**

Test Property	Test procedures/requirements	Rating/ Result
Castor chair test (EN 425:2002)	<ol style="list-style-type: none"> <li>Condition the test pieces at a temperature of (23±2) °C and relative humidity (50±5) % for a minimum of 24 h.</li> <li>Inspect the surface of the castors, if necessary , clean them with a cotton pad impregnated with denatured ethanol, and dry them. Pre-clean the test piece with a vacuum cleaner.</li> <li>Fix the base for the test piece on the circular plate, and lower the triangular platform to allow the castors to come into contact with the test piece. Preset the counter for 25000 revolutions of the plate and set the apparatus in motion with the suction device being operated continuously.</li> <li>Carry out the test within the temperature range of 18 °C to 25 °C.</li> <li>At the end of the test, examine the test piece for appearance change from a distance of approximately 800 mm at an approximate angle of 45° and from all directions by slowly rotating the viewing table.</li> <li>Record any damage caused by detachment of layers, opening of joints, or crazing. Ignore any flattening or change in appearance, e.g. change in gloss.</li> </ol>	Pass No damage was found after test



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.  
 Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: [CN\\_Doccheck@sgs.com](mailto:CN_Doccheck@sgs.com)

SGS-CSTC (Shanghai) Technical Services Co., Ltd. 4<sup>th</sup> Building, No.889, Yishan Road, Xuhui District Shanghai, China 200233 t (86) 400 960 9661 f (86-21) 6115 6899 www.sgs.com.cn  
 中国·上海·徐汇区宜山路889号4号楼 邮编: 200233 t (86) 400 960 9661 f (86-21) 6115 6899 e [sgs.china@sgs.com](mailto:sgs.china@sgs.com)

## Test Report

No.: SHHL1809053180BM


Date: Apr. 12, 2025 Page: 3 of 3

### Sample Photo:

Test sample (front side)



Test sample (back side)



SGS authenticate the photo on original report only

\*\*\*End of Report\*\*\*



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: [CN.Doccheck@sgs.com](mailto:CN.Doccheck@sgs.com)

SGS-CSTC Technical Services (Shanghai) Co., Ltd.  
Testing Center Harbin

4<sup>th</sup> Building, No.889, Yishan Road, Xuhui District Shanghai, China 200233

t (86) 400 960 9661

f (86-21) 6115 6899

[www.sgs.com](http://www.sgs.com)

中国·上海·徐汇区宜山路889号4号楼 邮编: 200233

t (86) 400 960 9661

f (86-21) 6115 6899

e [sgs.china@sgs.com](mailto:sgs.china@sgs.com)